

No. 10(6)/E.S.F./PUR./2013-14

NATIONAL SUGAR INSTITUTE

(GOVERNMENT OF INDIA)

MINISTRY OF CONSUMER AFFAIRS, FOOD & PUBLIC DISTRIBUTION
(DEPARTMENT OF FOOD & PUBLIC DISTRIBUTION)
KANPUR

PHONE : 2570541,542,543
Fax : 0512-2570247
E-Mail ID : nsikanpur@nic.in
Website : http://nsi.gov.in

Dated: 23.10.2013

TENDER NOTICE

Sealed tenders are invited for and on behalf of President of India by the Director, National Sugar Institute, Kanpur for procurement of Boiler Control Panel for use in Experimental Sugar Factory attached with this Institute from reputed Manufacturers/Authorized distributors/Authorized dealers.

The other details are available in the tender document which may be downloaded from the Institute's website <http://nsi.gov.in>. from the date of publication. The document fees in form of Demand Draft of Rs. 500/- in favour of Director, National Sugar Institute, Kalyanpur, Kanpur is to be enclosed with the tender.

Date of tender submission is on or before dated 13-11-2013 at 3.00 P.M. and shall be opened on the same day.



(ABHAI KUMAR)
Admin.-Cum.-Purchase & Sales Officer

NATIONAL SUGAR INSTITUTE
(GOVERNMENT OF INDIA)
MINISTRY OF CONSUMER AFFAIRS, FOOD & PUBLIC DISTRIBUTION
(DEPARTMENT OF FOOD & PUBLIC DISTRIBUTION)
KANPUR

Phone : 2570541,542,543
Fax : 0512-2570247
E-Mail ID : nsikanpur@nic.in
Website : http://nsi.gov.in

No. 10(6)/E.S.F./Pur./2013-14
Dated: 23.10.2013


TENDER DOCUMENT AGAINST TENDER NOTICE FOR BOILER CONTROL PANEL

For and on behalf of the President of India sealed tenders are invited by Director, National Sugar Institute, Kanpur for procurement of Boiler Control Panel, The details are given below:

Sl. No.	Particular Items	Quantity Required
1.	<p>Boiler Control Panel maximum working pressure-17.2kg/cm² MCR-4 Ton/Hrs., provision in panel are to be made as under :-</p> <p>(i) Steam drum pressure indicator (digital) with transmitter (Range 0-30 kg./cm²) (Output 4-20 mA.)</p> <p>(ii) Water drum pressure indicator (digital) with transmitter (Range 0-30 kg/cm².) (output 4-20mA)</p> <p>(iii) Steam flow indicator cum totaliter (digital) (Range 0-4 Te/hr) with D.P. transmitter output 4-20 mA & orifice plate & condensate pot.</p> <p>(iv) Water flow indicator cum totaliter (digital) (Range 0-4 Te/hr) with D.P. transmitter output 4-20MA & orifice plate.</p> <p>(v) Multipoint temperature indicator with thermocouple as sensor (for steam line, main bank gas output, Air heater Air output, Air heater gas output.)</p> <p>(vi) Boiler drum level indication (digital) with transmitter. (Output 4-20mA).</p> <p>Note:- (scope of work) Turn key supply & installation of new control panel, Dismantling of existing panel, Erection, commissioning & successful trial of new panel will be managed or done by supplier or contractor along with related materials required (like copper tubings wiring etc) for which supplier may visit site before submitting quotation.</p>	One Complete Set

Terms & Conditions:

1. Parties should have PAN and TIN No.
2. Manufacturers/Authorized distributors/Authorized dealers may quote the rates by depositing fixed deposit Receipts @ 2% of the quoted amount pledged in the name of Director, National Sugar Institute, Kanpur.
3. The supply in all respect shall have to be made within 30 days from the date of issue of order.
4. The E.M.D. shall be returned after the satisfactory completion of supply in the event the offer is accepted.
5. Under no condition the Institute shall entertain advance payment or part of payment against part supply. This point is very clear and pertinent for submitting offer.
6. All the quotees are requested to submit their PAN/TIN details and taxes applicable as breakup of the quoted rate.
7. The Director, National Sugar Institute, Kanpur reserves the right to reject any or all the tender offers, without assigning any reason.
8. The last date for the submission of offer shall be ... 13-11-2013 ... up to 3.00 P.M. and tender shall be opened on the same day after 3.00 P.M.


(ABHAI KUMAR)
Admin.-Cum.-Purchase & Sales Officer